

Secondary and Non-regulated Substances

Unregulated contaminant monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.

Substance	Unit	Recommended Upper Limits	Average Level and Range Detected	Year ¹ Sampled
Bromodichloromethane	ppb	0.19	0.683 ND - 2.05	2009
Chloride	ppm	250	96.6 ND - 168	2009
Hardness (Calcium)	ppm	250	24.5 22 - 27	2009
Iron	ppm	0.3	0.051 0.04 - 0.11	2009
Manganese	ppm	0.05	0.005 ND - 0.0152	2009
pH	su	6.5 - 8.5	7.68 6.5 - 8.31	2009
Sodium ²	ppm	50	123.25 36.1 - 240.0	2009
Sulfate	ppm	50	5.374 (average) ND - 14.3 (range)	2009
Total Dissolved Solids	ppm	500	335.33 160.0 - 666.0	2009
Dibromochloromethane	ppb	0.16	1.66 0.36 - 4.16	2009